

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF. FILE

DATE 6-8-84

DEPARTMENT

Re: Complaint at 225 S. Dysart

This office received a complaint on June 5, 1984, about stagnant water in front of 225 S. Dysart (Vita-Erb, Mr. Cliff Brown). Upon investigation it was found that Smitty's roof drains discharge to the drainage ditch on Dysart St. Smitty's was currently running their cooling tower with once through cooling water and discharging the water onto their roof. This apparently was causing water to flow north on Dysart St. The storm ditch in that area was in bad need of being cleaned, therefore the water was pooling out in several locations.

The City Street Dept. was contacted about the drainage problem. Cleaning the ditch properly should take care of the situation.

5

SIGNED
DYSART

Gene Pabst

Gene Pabst